

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-1477:102 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Mircom Technologies Ltd, *25 Interchange Way, Vaughan, Ontario, Canada L4K 5W3
Contact: Mara Cherubin (888) 660-4655 FAX (888) 660-4113

DESIGN: Model FA-101U, -102U, -104/8U, -104/8UX and -1025U fire alarm control units. Non-coded; automatic, manual, local, waterflow and sprinkler supervisory service. System components:

DM-102S	Supervisory Board (2 Zone)
RM-104	Quad Relay Board
AM-108	Annunciator Driver Board
WM-101	Walk Test Board
DM-102	Detection (2 Zone)

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed electrically and functionally compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to listee's Installation Manual for details.

*Rev. 11-04-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**